


RSLOGIX **5000** ERROR CODES WHEN USING ETHERNET IP AND ABB DRIVES

Description:

The RSLogix 5000 Error Codes or Module Fault # can be found under the connection Tab within the RSlogix 5000 software.

Right click on the Generic Ethernet Module and select Properties.



	Author: Jeff Fell – Application Eng.		Date: Nov 17, 2016
	External		Document #:
	http://www.abb.us/drives	Industry – Industrial	Revision: B
Product Categories: RETA-01, FENA-xx			



	n Tab.	
Module Properties Report: Loc	alENB (ETHERNET-MODULE 1.1)	23
ieneral Connection Module Inf	0	
Requested Packet Interval (RPI):	10.0 ms (1.0 - 3200.0 ms)	
🔝 Inhibit Module		
Major Fault On Controller If Co	nnection Fails While in Run Mode	
Vise Unicast Connection over	EtherNet/IP	
Module Fault		
	equest Error: Connection request timed out.	
	equest Error: Connection request timed out.	
	equest Error: Connection request timed out.	
	equest Error: Connection request timed out.	
	equest Error: Connection request timed out.	
	equest Error: Connection request timed out.	
	equest Error: Connection request timed out.	Help

The Error Codes or Module Fault # can be found in the following location.

Error Code 16#0204 = Connection Request Error: Connection request timed out.

Reason: The PLC can't locate the Drive at the given IP Address.

Things to check:

- □ Check to make sure DHCP is disabled if a Static IP Address is being programmed in the drive.
- □ Check the programming of the IP address of the Drive and Subnet. Check the programming of the IP Address in the PLC for the drive.
- □ Try to ping the drives IP address via a PC connected to the same network.
- $\hfill\square$ Locate and correct the IP address problem.
- \Box Check network wiring.

Error Code 16#012a = Connection Request Error: Invalid output application path.

Reason: There is a mismatch in the selected profile between the PLC and Drive.

Things to check:

- □ Check the Profile setting in the drive (FENA-xx parameter 51.02 or RETA-01 51.16) for the selected Assembly Instances that where chosen in the PLC.
- □ There is a mismatch in the selected profile (example the drive is programmed for ODVA Profile and the PLC is programmed for ABB Profile).

Author: Jeff Fell – Application Eng.		Date: Nov 17, 2016
External		Document #:
http://www.abb.us/drives	Industry – Industrial	Revision: B
Product Categories: RETA-01, FENA-xx		



Error Code 16#0127 = Connection Request Error: Invalid output size.

Reason: The connection words size is too large to fit in the programmed word array size in the PLC.

Things to check:

- □ Check the programmed connection size in the PLC and the drive (example the drive is sending 13 words and the PLC is programmed to 10 words).
- \Box Also check to make sure the Comm Format is programmed to Data INT in the PLC.

Error Code 16#0005 = Connection Request Error: Bad Class.

Reason: There is a mismatch in the selected profile between the PLC and Drive.

Things to check:

- □ Check the Profile setting in the drive (FENA-xx parameter 51.02 or RETA-01 51.16) for the selected Assembly Instances that were chosen in the PLC.
- □ There is a mismatch in the selected profile (example the drive is programmed for ODVA Profile and the PLC is programmed for ABB Profile).
- □ Also check the programmed connection size in the PLC and the drive (example the drive is sending 2 words and the PLC is programmed to 6 words).
- □ Also check to make sure the Comm Format is programmed to Data INT in the PLC.

Error Code 16#0109 = Connection Request Error: Invalid connection size (Invalid Input size).

Reason: The connection words size for the Input is too large to fit in the programmed word array size in the PLC.

Things to check:

- □ Check the programmed connection size in the PLC and the drive (example the drive is sending 2 words and the PLC is programmed to 4 words).
- □ Also check to make sure the Comm Format is programmed to Data INT in the PLC.

Error Code 16#0111 = Requested Packet Interval (RPI) out of range.

Reason: The programmed RPI rate is lower then allowed by the Fieldbus option.

Things to check:

□ Increase the RPI rate in RSLogix 5000, this can be found under the Connection Tab.

Author: Jeff Fell – Application Eng.		Date: Nov 17, 2016
External		Document #:
http://www.abb.us/drives	Industry – Industrial	Revision: B
Product Categories: RETA-01, FENA-xx		



Documents or other reference material:

FENA-01/-11/-21 Ethernet adapter module user's manual	3AUA0000093568
Basic Guide to Communications ODVA (ControlNet, DeviceNet and EtherNet/IP), US	LVD-PNTG03U-EN
RETA-01 Ethernet Adapter Module User's Manual	3AFE64539736

Corrective Actions:

Follow the instructions above.

Author: Jeff Fell – Application	n Eng.	Date: Nov 17, 2016
External		Document #:
http://www.abb.us/drives	Industry – Industrial	Revision: B
Product Categories: RETA-01, FENA-xx		